

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7254-0087:134 Page 1 of 1

CATEGORY: Heat Detector (Single/Multiple)

LISTEE: BRK, 3901 Liberty Street Rd., Aurora, IL 60504-2495
Contact: *Mark Dippner (630) 851-7330 ext 1422 FAX (630) 851-9309

DESIGN: Models HD6135F single and multiple station, 120 VAC, fixed temperature heat detector. The unit is designed to be used as an added source of information and should be used in conjunction with smoke detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 135⁰F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as AC powered, single and multiple station fixed temperature heat detector. The detector can also generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to listee's Installation Instructions Manual for details.

*Rev. 6-09-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

*Listing Expires **June 30, 2009***

Authorized By: **BEN HO, Chief**
Fire Engineering Division