

Northbrook, Illinois • (847) 272-8800
 Melville, New York • (631) 271-6200
 Santa Clara, California • (408) 985-2400
 Research Triangle Park,
 North Carolina • (919) 549-1400
 Camas, Washington • (360) 817-5500



BRK BRANDS INC
 MR M DIPPNER
 3901 LIBERTY STREET RD
 AURORA IL 60504

Your most recent Certification is shown below. You may also view this information, or a portion of this information (depending on the product category), on UL's Online Certifications Directory at www.ul.com/database. Please review the text and contact the Conformity Assessment Services staff member who handled your project if revisions are required. For instructions on placing an order for this information in a 3 x 5-inch format, you may refer to the enclosed order form for UL Card Service.

UTFS September 24, 2002
 Single- and Multiple-Station Heat Detectors

BRK BRANDS INC
 3901 LIBERTY STREET RD, AURORA IL 60504

S7113

Single-station, Multiple-station.

Type	Supply Connection	Temp Rating	Max Smooth Ceiling Spacing	Max Distance to Wall or Partition	Model
SS/MS	120Vac	135 F	50 ft apart	25 ft	HD6135F
SS/MS	120 W battery backup	135 F	50 ft apart	25 ft	HD6135FB

Code: SS-Single station, MS-Multiple station.

LOOK FOR LISTING MARK ON PRODUCT