

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 5276-0087:0157

CATEGORY: 5276 -- CARBON MONOXIDE ALARMS

LISTEE: BRK BRANDS, INC. 3901 W. Liberty Street Road, Aurora, IL 60504-8122
Contact: Mark Dippner (630) 851-7330 Ext: 1422 Fax (630) 851-9309
Email: Mdippner@jardensafety.com

DESIGN: Model "First Alert" CO250 single station, battery battery operated Carbon Monoxide alarm.
Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 9 VDC battery

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes, NFPA 720,
and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or "First Alert" , model number, and ETL label.

APPROVAL: Listed as Carbon Monoxide alarms for residential applications.

NOTE: Carbon Monoxide alarms are not intended/suitable for fire and smoke detection.

12-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **December 09, 2010**

Listing Expires **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division